



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2710

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Evergreen Apt.*

Address: *3730 Evergreen Dr.*
Monroeville, PA 15146

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: 6/22/26
Time: 3:36 PM
Method: *Grab*

Sample Final Analysis

Date: 6/24/26
Time: 1:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/23/26	1:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/23/26	1:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/22/26	6:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/22/26	3:36 PM	DW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/22/26	3:36 PM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/22/26	3:36 PM	DW	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)