



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2444

Customer

Facility Name: Riverview
Address: 400 Riverview Ave.
Pittsburgh, PA 15214

Sample Collection

Date: 6/22/26
Time: 1:30 PM
Method: Grab

Sample Final Analysis

Date: 6/24/26
Time: 9:30 AM
Analyst: AS

Matrix: Recreational Water

Source Type: Shallow End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/23/26 9:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/23/26 9:00 AM	AH	SM 9222B
Standard plate count:	220/ml	200/ml	6/22/26 3:50 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	6/22/26 1:30 PM	WB	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/22/26 1:30 PM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/22/26 1:30 PM	WB	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)