



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 253

Customer

Facility Name: *Perry Traditional Academy*

Address: *3875 Perrysville Ave.
Pittsburgh, PA 15214*

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection

Date: *6/22/26*

Time: *11:09 AM*

Method: *Grab*

Sample Final Analysis

Date: *6/24/26*

Time: *10:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	6/23/26	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	A	6/23/26	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	A	6/22/26	5:00 PM	AS	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.7 SU	B	6/22/26	11:09 AM	JT	DPD
Chlorine:	7.5 mg/l	E	6/22/26	11:09 AM	JT	DPD
Turbidity:	1 NTU	A	6/22/26	11:09 AM	JT	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)