



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2015

Customer

Facility Name: Allegheny C.C.

Address: 250 Country Club Rd
Sewickley, PA 15143

Matrix: Recreational Water

Source Type: Baby Pool

Sample Collection

Date: 7/28/26

Time: 2:04 PM

Method: Grab

Sample Final Analysis

Date: 7/31/26

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/26	9:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/26	9:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/26	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/28/26	2:04 PM	SL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/28/26	2:04 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/26	2:04 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor