



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-15**

**Lab# 2811**

**Customer**

Facility Name: Amherst Village

Address: 2022 Shelly Ln.  
Mars, PA 16046

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 6/3/26

Time: 12:43 PM

Method: Grab

**Sample Final Analysis**

Date: 6/5/26

Time: 6:30 PM

Analyst: AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |         | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 6/3/26               | 6:20 PM | SL      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/3/26               | 6:20 PM | SL      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 6/3/26               | 6:20 PM | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |          | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH:            | 7.4 SU   | 7.2 - 7.8 SU    | 6/3/26    | 12:43 PM | MM      | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | 6/3/26    | 12:43 PM | MM      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 6/3/26    | 12:43 PM | MM      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor