



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-14**

**Lab# 2021**

**Customer**

**Facility Name:** Ascent 430  
**Address:** 430 Ascent Dr.  
Marshall Twp., PA 15086

**Sample Collection**

**Date:** 6/8/26  
**Time:** 10:35 AM  
**Method:** Grab

**Matrix:** Recreational Water  
**Source Type:** Pool

**Sample Final Analysis**

**Date:** 6/11/26  
**Time:** 10:30 AM  
**Analyst:** AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 6/9/26 10:00 AM      | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/9/26 10:00 AM      | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 6/8/26 4:09 PM       | AS      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time       | Analyst | Method |
|----------------|----------|-----------------|-----------------|---------|--------|
| pH:            | 7.0 SU   | 7.2 - 7.8 SU    | 6/8/26 10:35 AM | EG      | DPD    |
| Chlorine:      | 7.5 mg/l | 1.0 - 5.0 mg/l  | 6/8/26 10:35 AM | EG      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 6/8/26 10:35 AM | EG      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor