



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
N-12

Lab# 2023

Customer

Facility Name: Avalon Boro

Address: 629 New Brighton Rd.
Avalon, PA 15202

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 6/15/26

Time: 2:15 PM

Method: Grab

Sample Final Analysis

Date: 6/18/26

Time: 11:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/16/26	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/16/26	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/15/26	5:50 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/15/26	2:15 PM	IS	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/15/26	2:15 PM	IS	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/15/26	2:15 PM	IS	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)