



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 063

Customer

Facility Name: *Comfort Inn - Meadowlands*

Address: *237 Meadowlands Boulevard
Washington, PA 15301*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/27/26*

Time: *2:20 PM*

Method: *Grab*

Sample Final Analysis

Date: *7/30/26*

Time: *11:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/28/26	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/28/26	11:00 AM	AH	SM 9222B
Standard plate count:	570/ml	200/ml	7/27/26	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/27/26	2:20 PM	EB	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/27/26	2:20 PM	EB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/27/26	2:20 PM	EB	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)