Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-2

Lab# 465

Customer

Facility Name: *Towers Pool*

Address: *1206 Bluff St.*
Pittsburgh, PA 15282

Matrix: *Recreational Water*

Source Type: *Pool Deep*

Sample Collection

Date: *2/24/26*
Time: 11:15 AM
Method: *Grab*

Sample Final Analysis

Date: *2/26/26*
Time: *10:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	2/25/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/25/26	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	2/24/26	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	2/24/26	11:15 AM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	2/24/26	11:15 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/24/26	11:15 AM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor