



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2169

Customer

Facility Name: Edgewood Club
Address: 1 Pennwood Ave.
Pittsburgh, PA 15218

Sample Collection

Date: 7/27/26
Time: 9:52 AM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 7/30/26
Time: 3:00 PM
Analyst: AS

Source Type: Deep End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/28/26	2:30 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/28/26	2:30 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/27/26	6:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/27/26	9:52 AM	DW	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/27/26	9:52 AM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/27/26	9:52 AM	DW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor