



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 2165

Customer

Facility Name: Edgetown Condo
Address: 205 Coraopolis Rd.
Coraopolis, PA 15108

Sample Collection

Date: 7/28/26
Time: 9:18 AM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 7/31/26
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/26	9:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/26	9:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/26	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/28/26	9:18 AM	SL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/28/26	9:18 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/26	9:18 AM	SL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)