



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-15

Lab# 2179

Customer

Facility Name: *Estates of Seven Fields*

Address: *260 Jameson Way
Sevenfields, PA 16046*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *5/11/26*

Time: *8:55 AM*

Method: *Grab*

Sample Final Analysis

Date: *5/14/26*

Time: *10:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/12/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/12/26	10:00 AM	SL	SM 9222B
Standard plate count:	100/ml	200/ml	5/11/26	5:07 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.2 SU	7.2 - 7.8 SU	5/11/26	8:55 AM	SH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	5/11/26	8:55 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/11/26	8:55 AM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor