



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-16

Lab# 2662

Customer

Facility Name: Hampton Twp
Address: 3101 McCully Rd.
Allison Park, PA 15101

Sample Collection

Date: 6/15/26
Time: 10:58 AM
Method: Grab

Sample Final Analysis

Date: 6/18/26
Time: 12:30 PM
Analyst: AS

Matrix: Recreational Water

Source Type: Shallow End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/16/26	12:00 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/16/26	12:00 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	6/15/26	6:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/15/26	10:58 AM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/15/26	10:58 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/15/26	10:58 AM	MM	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)