



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 2242

Customer

Facility Name: Hawthorne Commons
Address: 214 Sycamore Dr.
Seven Fields, PA 16046

Sample Collection

Date: 7/30/26
Time: 11:39 AM
Method: Grab

Sample Final Analysis

Date: 8/1/26
Time: 4:00 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/26	3:45 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/26	3:45 PM	SL	SM 9222B
Standard plate count:	125/ml	200/ml	7/30/26	3:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.3 SU	7.2 - 7.8 SU	7/30/26	11:39 AM	SL	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/30/26	11:39 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/30/26	11:39 AM	SL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)