



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-15

Lab# 151

Customer

Facility Name: Hilton Garden Inn
Address: 1000 Corporate Drive
Canonsburg, PA 15317

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/28/26
Time: 2:10 PM
Method: Grab

Sample Final Analysis

Date: 7/31/26
Time: 11:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/26	10:40 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/26	10:40 AM	MD	SM 9222B
Standard plate count:	100/ml	200/ml	7/28/26	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/28/26	2:10 PM	EB	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/28/26	2:10 PM	EB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/26	2:10 PM	EB	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)