



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-13**

**Lab# 168**

**Customer**

Facility Name: Home2Suites  
Address: 8630 Duncan Ave.  
Pittsburgh, PA 15237

**Sample Collection**

Date: 6/16/26  
Time: 11:40 AM  
Method: Grab

Matrix: Recreational Water  
Source Type: Pool

**Sample Final Analysis**

Date: 6/19/26  
Time: 10:30 AM  
Analyst: AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 6/17/26 10:00 AM     | SL      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/17/26 10:00 AM     | SL      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 6/16/26 3:35 PM      | AH      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time        | Analyst | Method |
|----------------|----------|-----------------|------------------|---------|--------|
| pH:            | 7.4 SU   | 7.2 - 7.8 SU    | 6/16/26 11:40 AM | IS      | DPD    |
| Chlorine:      | 4.0 mg/l | 1.0 - 5.0 mg/l  | 6/16/26 11:40 AM | IS      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 6/16/26 11:40 AM | IS      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor