



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 2277

Customer

Facility Name: *Hunting Ridge*

Address: *401 Meeting House Rd.
Bridgeville, PA 15017*

Matrix: *Recreational Water*

Source Type: *Deep End*

Sample Collection

Date: *5/18/26*

Time: *11:42 AM*

Method: *Grab*

Sample Final Analysis

Date: *5/21/26*

Time: *10:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/19/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/19/26	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	5/18/26	3:31 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/18/26	11:42 AM	JT	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/18/26	11:42 AM	JT	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/18/26	11:42 AM	JT	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor