



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-16**

**Lab# 177**

**Customer**

**Facility Name:** Hyatt Place  
**Address:** 2112 Racetrack  
Washington, PA 15301

**Sample Collection**

**Date:** 5/19/26  
**Time:** 8:55 AM  
**Method:** Grab

**Matrix:** Recreational Water

**Sample Final Analysis**

**Date:** 5/22/26  
**Time:** 11:30 AM  
**Analyst:** AS

**Source Type:** Pool

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 5/20/26              | 11:00 AM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 5/20/26              | 11:00 AM | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 5/19/26              | 5:40 PM  | AS      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 8.0 SU   | 7.2 - 7.8 SU    | 5/19/26   | 8:55 AM | AMH     | DPD    |
| Chlorine:      | 0.0 mg/l | 1.0 - 5.0 mg/l  | 5/19/26   | 8:55 AM | AMH     | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 5/19/26   | 8:55 AM | AMH     | Visual |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)