



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-10**

**Lab# 183**

**Customer**

**Facility Name:** Imperial House  
**Address:** 5600 Munhall Rd.  
Pittsburgh, PA 15217

**Sample Collection**

**Date:** 7/28/26  
**Time:** 11:30 AM  
**Method:** Grab

**Matrix:** Recreational Water  
**Source Type:** Pool

**Sample Final Analysis**

**Date:** 7/31/26  
**Time:** 12:00 PM  
**Analyst:** AS

| Accredited Analysis   | Results  | Reporting limit | Incubation | Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/29/26    | 11:40 AM  | MD      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/29/26    | 11:40 AM  | MD      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 7/28/26    | 6:30 PM   | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time | Analyst  | Method |        |
|----------------|----------|-----------------|-----------|----------|--------|--------|
| pH:            | 7.6 SU   | 7.2 - 7.8 SU    | 7/28/26   | 11:30 AM | DNP    | DPD    |
| Chlorine:      | 5.0 mg/l | 1.0 - 5.0 mg/l  | 7/28/26   | 11:30 AM | DNP    | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 7/28/26   | 11:30 AM | DNP    | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor