



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-12

Lab# 2288

Customer

Facility Name: *Ingomar Swim Club*
Address: *1512 Ingomar Heights Rd.*
Pittsburgh, PA 15237

Sample Collection

Date: *6/22/26*
Time: *10:15 AM*
Method: *Grab*

Sample Final Analysis

Date: *6/25/26*
Time: *11:00 AM*
Analyst: *AS*

Matrix: *Recreational Water*
Source Type: *Deep End*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/23/26	10:30 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/23/26	10:30 AM	MD	SM 9222B
Standard plate count:	5/ml	200/ml	6/22/26	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.7 SU	7.2 - 7.8 SU	6/22/26	10:15 AM	IS	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/22/26	10:15 AM	IS	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/22/26	10:15 AM	IS	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)