



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-10**

**Lab# 190**

**Customer**

**Facility Name:** Jewish Community Cntr

**Address:** 5738 Forbes Ave.  
Pittsburgh, PA 15217

**Matrix:** Recreational Water

**Source Type:** Women - Spa

**Sample Collection**

**Date:** 7/28/26

**Time:** 12:00 PM

**Method:** Grab

**Sample Final Analysis**

**Date:** 8/1/26

**Time:** 12:00 PM

**Analyst:** AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                   |        |        |                  |    |          |
|-------------------|--------|--------|------------------|----|----------|
| Escherichia Coli: | Absent | Absent | 7/29/26 11:40 AM | MD | SM 9222G |
|-------------------|--------|--------|------------------|----|----------|

|                  |           |          |                  |    |          |
|------------------|-----------|----------|------------------|----|----------|
| Total coliforms: | 50/100mls | 2/100mls | 7/29/26 11:40 AM | MD | SM 9222B |
|------------------|-----------|----------|------------------|----|----------|

|                       |         |        |                 |    |          |
|-----------------------|---------|--------|-----------------|----|----------|
| Standard plate count: | 5700/ml | 200/ml | 7/28/26 6:30 PM | SL | SM 9215B |
|-----------------------|---------|--------|-----------------|----|----------|

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                     |          |          |                  |    |          |
|---------------------|----------|----------|------------------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 7/29/26 10:35 AM | SL | SM 9230C |
|---------------------|----------|----------|------------------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

|     |        |              |                  |     |     |
|-----|--------|--------------|------------------|-----|-----|
| pH: | 7.8 SU | 7.2 - 7.8 SU | 7/28/26 12:00 PM | DNP | DPD |
|-----|--------|--------------|------------------|-----|-----|

|           |          |                |                  |     |     |
|-----------|----------|----------------|------------------|-----|-----|
| Chlorine: | 0.0 mg/l | 1.0 - 5.0 mg/l | 7/28/26 12:00 PM | DNP | DPD |
|-----------|----------|----------------|------------------|-----|-----|

|            |       |           |                  |     |        |
|------------|-------|-----------|------------------|-----|--------|
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/28/26 12:00 PM | DNP | Visual |
|------------|-------|-----------|------------------|-----|--------|

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)