



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# 215

Customer

Facility Name: Longwood at Oakmont

Address: 500 Route 909
Verona, PA 15147

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/15/26

Time: 10:20 AM

Method: Grab

Sample Final Analysis

Date: 6/18/26

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/16/26	10:00 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/16/26	10:00 AM	AS	SM 9222B
Standard plate count:	20/ml	200/ml	6/15/26	4:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/15/26	10:20 AM	LL	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/15/26	10:20 AM	LL	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/15/26	10:20 AM	LL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor