



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
S-10

Lab# 417

Customer

Facility Name: *Mt. Lebanon High School*

Address: *155 Cochran Rd,
Pittsburgh, PA 15228*

Matrix: *Recreational Water*

Source Type: *Deep End*

Sample Collection

Date: *5/26/26*

Time: *1:07 PM*

Method: *Grab*

Sample Final Analysis

Date: *5/29/26*

Time: *12:30 PM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/27/26	12:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/27/26	12:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/26/26	4:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/26/26	1:07 PM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/26/26	1:07 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/26/26	1:07 PM	SL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)