



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-13

Lab# 2385

Customer

Facility Name: Oxford Athletic
Address: 100 Village Club Dr.
Wexford, PA 15090

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 6/16/26
Time: 9:40 AM
Method: Grab

Sample Final Analysis

Date: 6/19/26
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/26	3:35 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	6/16/26	9:40 AM	IS	DPD
Chlorine:	1.5 mg/l	1.0 - 5.0 mg/l	6/16/26	9:40 AM	IS	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/26	9:40 AM	IS	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor