



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2395

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: Parkside Estates

Address: 202 Ketchum Court
Cannonsburg, PA 15317

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/27/26
Time: 3:20 PM
Method: Grab

Sample Final Analysis

Date: 7/30/26
Time: 12:00 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/28/26	11:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/28/26	11:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/27/26	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/27/26	3:20 PM	EB	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/27/26	3:20 PM	EB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/27/26	3:20 PM	EB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor