



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**Service**

**Lab# 311**

**Customer**

**Facility Name:** UPMC Lemieux Sports Complex

**Address:** 8000 Cranberry Springs Drive  
Cranberry Township, PA 16066

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 7/28/26

**Time:** 11:20 AM

**Method:** Grab

**Sample Final Analysis**

**Date:** 7/31/26

**Time:** 10:30 AM

**Analyst:** AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/29/26              | 10:15 AM | SL      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/29/26              | 10:15 AM | SL      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 7/28/26              | 7:00 PM  | SL      | SM 9215B |
| Additional Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
| Fecal Streptococcus   | 0/100mls | 2/100mls        | 7/29/26              | 10:35 AM | SL      | SM 9230C |
| Field Analysis        | Results  | Reporting limit | Date/Time            |          | Analyst | Method   |
| pH:                   | 8.0 SU   | 7.2 - 7.8 SU    | 7/28/26              | 11:20 AM | LB      | DPD      |
| Chlorine:             | 6.8 mg/l | 1.0 - 5.0 mg/l  | 7/28/26              | 11:20 AM | LB      | DPD      |
| Turbidity:            | 1 NTU    | 1 - 2 NTU       | 7/28/26              | 11:20 AM | LB      | Visual   |

**Sample comments**

*Andre Smith*

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)