



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# 259

Customer

Facility Name: Providence Pointe
Address: 301 Kane Boulevard
Pittsburgh, PA 15243

Matrix: Recreational Water
Source Type: Spa

Sample Collection

Date: 5/26/26
Time: 11:14 AM
Method: Grab

Sample Final Analysis

Date: 5/29/26
Time: 12:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/27/26	12:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/27/26	12:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/26/26	4:50 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	1/0/00	2:30 PM	0	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/26/26	11:14 AM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/26/26	11:14 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/26/26	11:14 AM	SL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)