



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 2785

Customer

Facility Name: *Quality Inn Cranberry*

Address: *30 St. Francis Way
Cranberry, PA 16066*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *6/8/26*

Time: *11:50 AM*

Method: *Grab*

Sample Final Analysis

Date: *6/11/26*

Time: *10:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/9/26 10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/9/26 10:00 AM	AH	SM 9222B
Standard plate count:	10/ml	200/ml	6/8/26 4:09 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	6/8/26 11:50 AM	EG	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/8/26 11:50 AM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/8/26 11:50 AM	EG	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)