



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-16

Lab# 2306

Customer

Facility Name: *Kiwanis Park Pool*
Address: *1 Meyer Rd.*
Glenshaw, PA 15116

Sample Collection

Date: *5/27/26*
Time: *7:57 AM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Deep End*

Sample Final Analysis

Date: *5/30/26*
Time: *11:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/26	11:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/26	11:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/26	6:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	5/27/26	7:57 AM	MM	DPD
Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	5/27/26	7:57 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/26	7:57 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor