



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-13

Lab# 281

Customer

Facility Name: South Fayette H.S.
Address: 3640 Old Oakdale Road
McDonald, PA 15057

Sample Collection

Date: 7/28/26
Time: 8:10 AM
Method: Grab

Sample Final Analysis

Matrix: Recreational Water
Source Type: Deep End

Date: 7/31/26
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/26	9:00 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/26	9:00 AM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/26	4:20 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/28/26	8:10 AM	AMH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/28/26	8:10 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/26	8:10 AM	AMH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor