



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 2506

Customer

Facility Name: *St Clair Country Club*
Address: *2300 Old Washington Rd.*
Pittsburgh, PA 15241

Sample Collection

Date: *5/11/26*
Time: *12:00 PM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Baby Pool*

Sample Final Analysis

Date: *5/14/26*
Time: *11:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/12/26	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/12/26	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	1/0/00	4:09 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.7 SU	7.2 - 7.8 SU	5/11/26	12:00 PM	JT	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/11/26	12:00 PM	JT	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/11/26	12:00 PM	JT	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor