



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 2507

Customer

Facility Name: *Stanford Court*
Address: *1200 Stanford Ct.*
Coraopolis, PA 15108

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/28/26*
Time: *9:39 AM*
Method: *Grab*

Sample Final Analysis

Date: *7/31/26*
Time: *12:00 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/26	11:40 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/26	11:40 AM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/26	6:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/28/26	9:39 AM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/28/26	9:39 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/26	9:39 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor