



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-15

Lab# 388

Customer

Facility Name: Towne Place Suites
Address: 2020 Cool Springs Dr.
Cranberry Township, PA 16066

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/24/26
Time: 11:36 AM
Method: Grab

Sample Final Analysis

Date: 6/27/26
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/26	9:45 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/26	9:45 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/26	4:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	6/24/26	11:36 AM	EG	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/24/26	11:36 AM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/26	11:36 AM	EG	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor