



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-16

Lab# 2534

Customer

Facility Name: *Treesdale Golf & CC*

Address: *1 Arnold Palmer Dr.
Gibsonia, PA 15044*

Matrix: *Recreational Water*

Source Type: *Baby Pool*

Sample Collection

Date: *6/22/26*

Time: *10:36 AM*

Method: *Grab*

Sample Final Analysis

Date: *6/25/26*

Time: *12:30 PM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/23/26	12:00 PM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/23/26	12:00 PM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	6/22/26	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/22/26	10:36 AM	MM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/22/26	10:36 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/22/26	10:36 AM	MM	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)