



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 304

Customer

Facility Name: University of Pittsburgh
Address: 3501 Allequippa St.
Pittsburgh, PA 15260

Sample Collection

Date: 5/12/26
Time: 10:00 AM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 5/14/26
Time: 10:30 AM
Analyst: AS

Source Type: Lg Pool Shallow

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/13/26	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/13/26	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	1/0/00	3:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/12/26	10:00 AM	JT	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/12/26	10:00 AM	JT	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/12/26	10:00 AM	JT	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

Andre Smith, Lead Supervisor