



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-15

Lab# 2803

Customer

Facility Name: Villas at Spring Valley

Address: 100 Spring Valley Dr.
Zelienople, PA 16063

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 5/19/26

Time: 9:24 AM

Method: Grab

Sample Final Analysis

Date: 5/22/26

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/20/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/20/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	5/19/26	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/19/26	9:24 AM	JMH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/19/26	9:24 AM	JMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/19/26	9:24 AM	JMH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)