



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-13

Lab# 2741

Customer

Facility Name: West Newton Community Pool

Address: 200 Peach Alley
West Newton, PA 15089

Matrix: Recreational Water

Source Type: Baby Pool

Sample Collection

Date: 5/26/26

Time: 3:15 PM

Method: Grab

Sample Final Analysis

Date: 5/29/26

Time: 12:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/27/26	12:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/27/26	12:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/26/26	4:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	5/26/26	3:15 PM	SH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	5/26/26	3:15 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/26/26	3:15 PM	SH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)