



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-15

Lab# 482

Customer

Facility Name: YMCA - Schneider
Address: 2001 Ehrman Rd
Cranberry, PA 16066

Sample Collection

Date: 6/2/26
Time: 2:30 PM
Method: Grab

Sample Final Analysis

Date: 6/5/26
Time: 11:30 AM
Analyst: AS

Matrix: Recreational Water
Source Type: Large Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/26	11:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/26	11:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/26	6:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	6/2/26	2:30 PM	EG	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/2/26	2:30 PM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/26	2:30 PM	EG	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)