



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-13

Lab# 360

Customer

Facility Name: YMCA - Mon-Valley
Address: 101 Taylor Run Road
Monongahela, Pa 15063

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 5/18/26
Time: 9:15 AM
Method: Grab

Sample Final Analysis

Date: 5/21/26
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/19/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/19/26	10:00 AM	JC	SM 9222B
Standard plate count:	100/ml	200/ml	5/18/26	3:31 PM	AH	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	1/0/00	12:00 AM	0	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/18/26	9:15 AM	MB	DPD
Chlorine:	3.8 mg/l	1.0 - 5.0 mg/l	5/18/26	9:15 AM	MB	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/18/26	9:15 AM	MB	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)