



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-13

Lab# 360

Customer

Facility Name: YMCA - Mon-Valley

Address: 101 Taylor Run Road
Monongahela, Pa 15063

Sample Collection

Date: 7/27/26
Time: 3:00 PM
Method: Grab

Sample Final Analysis

Date: 7/30/26
Time: 11:00 AM
Analyst: AS

Matrix: Recreational Water

Source Type: Spa

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/28/26	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/28/26	10:30 AM	AH	SM 9222B
Standard plate count:	100/ml	200/ml	7/27/26	6:00 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/28/26	2:30 PM	JC	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/27/26	3:00 PM	SH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/27/26	3:00 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/27/26	3:00 PM	SH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)