



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 2696

Customer

Facility Name: Venango Trails

Address: Aleah Dr.
Mars, PA 16046

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 5/28/26

Time: 11:00 AM

Method: Grab

Sample Final Analysis

Date: 5/31/26

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/26	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/26	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/26	5:25 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	5/28/26	11:00 AM	LL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/28/26	11:00 AM	LL	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/26	11:00 AM	LL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)