



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-15

Lab# 2635

Customer

Facility Name: Village Cranberry Woods Apt.

Address: 5001 Pendleton Way
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 5/19/26

Time: 11:25 AM

Method: Grab

Sample Final Analysis

Date: 5/22/26

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
---------------------	---------	-----------------	----------------------	--	---------	--------

Escherichia Coli:	Absent	Absent	5/20/26	10:00 AM	SL	SM 9222G
-------------------	--------	--------	---------	----------	----	----------

Total coliforms:	0/100mls	2/100mls	5/20/26	10:00 AM	SL	SM 9222B
------------------	----------	----------	---------	----------	----	----------

Standard plate count:	100/ml	200/ml	5/19/26	5:40 PM	AS	SM 9215B
-----------------------	--------	--------	---------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
---------------------	---------	-----------------	----------------------	--	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	5/20/26	11:00 AM	SL	SM 9230C
---------------------	----------	----------	---------	----------	----	----------

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
----------------	---------	-----------------	-----------	--	---------	--------

pH:	7.6 SU	7.2 - 7.8 SU	5/19/26	11:25 AM	JMH	DPD
-----	--------	--------------	---------	----------	-----	-----

Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	5/19/26	11:25 AM	JMH	DPD
-----------	----------	----------------	---------	----------	-----	-----

Turbidity:	1 NTU	1 - 2 NTU	5/19/26	11:25 AM	JMH	Visual
------------	-------	-----------	---------	----------	-----	--------

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)