



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 2572

Customer

Facility Name: Westmoreland Farms

Address: Wheatland Circle
Delmont, PA 15626

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/28/26

Time: 5:23 PM

Method: Grab

Sample Final Analysis

Date: 7/31/26

Time: 10:30 AM

Analyst: 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/26	10:15 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/26	10:15 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/26	7:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/28/26	5:23 PM	DW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/28/26	5:23 PM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/26	5:23 PM	DW	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)