



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2560

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Washington Gardens*
Address: *834 Washington Ave.*
 Carnegie, PA 15106

Sample Collection

Date: *7/27/26*
Time: *12:36 PM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Pool*

Sample Final Analysis

Date: *7/30/26*
Time: *11:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/28/26	11:00 AM	AH	SM 9222G

Total coliforms:	0/100mls	2/100mls	7/28/26	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/27/26	6:00 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	1/0/00	12:00 AM	0	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/27/26	12:36 PM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/27/26	12:36 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/27/26	12:36 PM	SL	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)