



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 3**

**Lab# 2774**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

*Facility Name:*      *Ltd. Findlay*  
*Address:*      *1001 Birdie Dr.*  
*Coraopolis, PA 15108*

**Sample Collection**

*Date:*      *7/21/26*  
*Time:*      *1:12 PM*  
*Method:*      *Grab*

*Matrix:*      *Recreational Water*  
*Source Type:*      *Pool*

**Sample Final Analysis**

*Date:*      *7/24/26*  
*Time:*      *10:00 AM*  
*Analyst:*      *AS*

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |         | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/22/26              | 9:40 AM | AS      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/22/26              | 9:40 AM | AS      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 7/21/26              | 4:30 PM | AS      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 8.0 SU   | 7.2 - 7.8 SU    | 7/21/26   | 1:12 PM | AHM     | DPD    |
| Chlorine:      | 2.0 mg/l | 1.0 - 5.0 mg/l  | 7/21/26   | 1:12 PM | AHM     | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 7/21/26   | 1:12 PM | AHM     | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor