



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 3**

**Lab# 2391**

**Customer**      *American Pools Management*  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

**Facility Name:**      *Park Place*  
**Address:**      *1700 Patrick Pl*  
                         *South Park, PA 15129*

**Sample Collection**  
**Date:**      *7/27/26*  
**Time:**      *12:10 PM*  
**Method:**      *Grab*

**Matrix:**      *Recreational Water*  
**Source Type:**      *Pool*

**Sample Final Analysis**  
**Date:**      *7/30/26*  
**Time:**      *10:30 AM*  
**Analyst:**      *AS*

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time  | Analyst | Method   |
|-----------------------|----------|-----------------|-----------------------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/28/26      10:00 AM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/28/26      10:00 AM | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 7/27/26      5:30 PM  | AH      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time             | Analyst | Method |
|----------------|----------|-----------------|-----------------------|---------|--------|
| pH:            | 7.2 SU   | 7.2 - 7.8 SU    | 7/27/26      12:10 PM | AV      | DPD    |
| Chlorine:      | 0.0 mg/l | 1.0 - 5.0 mg/l  | 7/27/26      12:10 PM | AV      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 7/27/26      12:10 PM | AV      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor