



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab ID No. 02-04041

S-15

Lab# 2665

Laboratory Analysis Report

Customer

Facility Name: *Georgetown Estates*
Address: *Old Farm Rd.*
Lawrence, PA 15055

Sample Collection

Date: *5/11/26*
Time: *11:10 AM*
Method: *Grab*

Sample Final Analysis

Date: *5/14/26*
Time: *11:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/12/26	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/12/26	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/11/26	4:09 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/11/26	11:10 AM	JT	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/11/26	11:10 AM	JT	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/11/26	11:10 AM	JT	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)