



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 2319

Customer

Facility Name: *Liberty Hills*
Address: *100 Liberty Lane*
Freedom, PA 15042

Sample Collection

Date: *6/23/26*
Time: *2:30 PM*
Method: *Grab*

Sample Final Analysis

Date: *6/26/26*
Time: *5:00 PM*
Analyst: *1/0/00*

Matrix: *Recreational Water*
Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/26	4:25 PM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/26	4:25 PM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/26	6:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/23/26	2:30 PM	EG	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/23/26	2:30 PM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/26	2:30 PM	EG	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor