



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 2631

Customer

Facility Name: Neville Side HOA
Address: 1900 Cambridge Dr.
Presto, PA 15142

Sample Collection

Date: 7/27/26
Time: 4:35 PM
Method: Grab

Sample Final Analysis

Date: 7/30/26
Time: 2:00 PM
Analyst: AS

Matrix: Recreational Water

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/28/26	1:30 PM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/28/26	1:30 PM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	7/27/26	6:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/27/26	4:35 PM	JB	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/27/26	4:35 PM	JB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/27/26	4:35 PM	JB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor