



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2019

Customer

Facility Name: Ammon

Address: 2217 Bedford Ave
Pittsburgh, PA 15219

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 7/28/26

Time: 1:00 PM

Method: Grab

Sample Final Analysis

Date: 7/31/26

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/26	9:00 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/26	9:00 AM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/26	4:20 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/28/26	1:00 PM	WB	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/28/26	1:00 PM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/26	1:00 PM	WB	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)